

Costs for WO #02-60456-0 AND ALL ASSOCIATED SUBS

MO.NO.....	Description.....	Part No	Part Noun Qual.....	Part Qty Issued	Tot Material Act	Act Tot Labor Cost	Actual Tot Cost
		18284	UNISTRUT, CHANNEL	80			
		5546	TERMINAL, 1 HOLE LUG	3			
		5144	TERMINAL, 1 HOLE LUG	20			
		58175	CONDUIT, FLEXIBLE	3			
		42670	ROD, ALLTHREAD	1			
		50620	ROD, ALLTHREAD	6			
		76757	LENS, BLUE	0			
		76762	LAMP, LED	0			
		20943	CLAMP, BEAM	6			
		18313	CLAMP, BEAM	0			
		70500	HARNES, FULL BODY	0			
		50236	CORD, PORTABLE	0			
		18240	WIRE (ELECT), THHN	0			
		8056	WIRE (ELECT), THHN	0			
		8054	WIRE (ELECT), THHN	0			
		18241	WIRE (ELECT), THHN	0			
		57701	FUSE, 045.00 AMP	0			
02-60456-49	UNIT 2 "CONTRACTOR COST TRACKER" (FOR DEAN WOOD) FOR STEAM DRUM MODIFICATIONS DURING OUTAGE.			0	0.00	0.00	0.00
02-60456-50	REPLACE THE PILLOWBLOCK BEARING INSERTS FOR THE OVERFIRE AIR DAMPER LINKAGE	73487	RESPIRATOR, FILTER	1	5,551.50	0.00	5,551.50
		D	LINKAGE BEARING WORK, OVERFIRE AIR, UNIT 1	0			
02-60456-51	TIME EXPENDED FOR GARY SPERRY AND RON WINTERS TO REMOVE 9TH FLOOR WALL BLOWERS FOR TEI.			0	0.00	0.00	0.00
02-60456-52	ELECTRICAL PREOUTAGE WORK FOR OVER-FIRE AIR INSTALLATION ON BOILER 9TH & 14TH FLOORS.			0	0.00	2,075.38	2,075.38
02-60456-53	RUN TEMP POWER FOR ADDITIONAL BOILER CONTRACTOR WORK BY TEI AT THE AIR HEATERS AND BURNERS. THERE WILL BE AT LEAST THREE TRAILERS, THEY WILL NEED 240V FEEDERS TO EACH, ALSO PHONES WILL BE PROVIDED ON A SEPERATE WORK ORDER.	D	SWITCH, DISCONNECT, SAFETY, 100 AMP, 3-PHASE, FUSED, 600 V, NEMA 3R, GROUNDING BUS BAR, HEAVY-DUTY, SIEMENS P/N HF363R, SQUARE D P/N H363RB	57	1,442.42	5,585.92	7,028.34
		D	FUSE, 100 AMP, 600 V, DUAL ELEMENT, BUSSMANN P/N FRSR100, FERRAZ P/N TRS100R	0			
		D	LUG KIT, GROUND, FOR 100 AMP	0			

IP7\_039452